

**CCR Unit: SCA #2 Ash Landfill**

**Owner: Sunnyside Cogeneration Associates**

**Annual Inspection: January 2018**

---

This annual inspection has been completed by S. Scott Carlson, PE 187727 in accordance with CCR Rules § 257.84 (b) and Utah State code R315-319-84.

1. Review of available information regarding the status and condition of the CCR unit:
  - a. Operating Record – Reviewed weekly inspection reports from Jan 2017 – Dec 2017.
  - b. Reviewed prior annual inspection (Jan 2017).
2. Conducted visual inspection of the CCR unit
  - a. Changes in the geometry of the structure since the previous annual inspection:
    - i. Additional CCR materials have been added to the Ash Landfill in accordance with approved design parameters
    - ii. Now filling on second lift. Upper haul road constructed and in use.
    - iii. Run-off control ditch is in place along south side of landfill. Surface of landfill slopes to prevent run-on from flowing across pile.
    - iv. Sediment Trap #1 and Sediment Pond 018 are in operation west (downhill) of the landfill. Sed Trap #1 cleaned in June & November 2017. No discharge recorded in 2017.
  - b. Approximate volume of CCR contained in the unit at the time of the inspection:
    - i. Prior year CCR approximate volume: 297,513 tons
    - ii. Current year CCR approximate volume added: 217,248 tons
    - iii. Approximate total volume at time of inspection: 514,761 tons
  - c. Appearances of an actual or potential structural weakness of the CCR unit, in addition to any existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit
    - i. None observed
  - d. Any other change(s) which may have affected the stability or operation of the CCR unit since the previous annual inspection.
    - i. None observed
3. Photo documentation attached: Yes

